

# **Department of Energy**

Richland Operations Office P.O. Box 550 Richland, Washington 99352

08-AMCP-0051

NOV 2 9 2007

Ms. Debra McBaugh, Section Head Environmental Radiation Section Washington State Department of Health P.O. Box 47827 Olympia, Washington 98504

Mr. David Grant Aquatic Resources Division State of Washington Department of Natural Resources 713 East Bowers Road Ellensburg, Washington 98926



#### Addressees:

DEPARTMENT OF NATURAL RESOURCES LAND LEASE MONITORING REPORT FOR NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT NO. WA 002591-7 OUTFALL 001 – OCTOBER 2007

The purpose of this letter is to forward for your review, the attached 300 Area Treated Effluent Disposal Facility, Department of Natural Resources monitoring data, as required by Aquatic Lands Sewer Outfall Lease 20-013357. The monitoring data for radionuclides present in the effluent are provided in the attached tables. The data indicate that all values monitored are well below State guidelines. Reporting of the sample results are provided and transmitted to the Washington State Department of Health, according to Exhibit C of the lease. This report covers the reporting period from September 25, 2007, through October 23, 2007.

If you have any questions, please contact me, or you may contact Mark French of my staff, on (509) 373-9863.

Sincerely,

AMCP:SKM

Attachment

cc: See Page 2

for the Central Plateau

cc w/attach:

G. Bohnee, NPT

A. L. Boyd, EPA

L. Buck, Wanapum

K. A. Conaway, Ecology

R. H. Engelmann, DFSH

D. L. Halgren, FHI

S. Harris, CTUIR

R. Jim, YN

K. Ogle, EPA (Seattle)

M. Priddy, WDOH

D. G. Ranade, FHI

E. R. Skinnarland, Ecology

H. T. Tilden, PNNL

Administrative Record (300 Area Treated Effluent H-0-7

Disposal Facility Liquid Effluent) and (Aquatic

Lands Sewer Outfall Lease 20-013357)

**Environmental Portal** 

# Hanford Site 300 Area Treated Effluent Disposal Facility

## Monthly Monitoring Data

## October 2007

Analysis	Result (pCi/L)	State Standard (pCi/L)
Total Alpha	BDL <sup>(2)</sup>	15 <sup>(3)</sup>
Total Beta	BDL <sup>(2)</sup>	50 <sup>(3)</sup>
GEA <sup>(1)</sup> – <sup>60</sup> Co	BDL <sup>(2)</sup>	3,000 <sup>(4)</sup> 1,000 <sup>(4)</sup>
Tritium	BDL <sup>(2)</sup>	20,000 <sup>(3)</sup>

(1) GEA: Gamma Energy Analysis

BDL: Below Detection Limit

Standards for total alpha, total beta, and tritium from Department of Natural Resources Aquatic Resources Lease 20-013357

Washington Administrative Code 246-221-290 (Table II, effluent water)